

NO SCALE

CostGard™ CONDENSATE DRAIN SEAL POSSIBLE INSTALLATION ARRANGEMENT FOR ALKERMES - #5768 - AHU-1

COOLING COIL &
DRAIN PAN
COMPARTMENT

SUPPLY FAN
COMPARTMENT

COOLING COIL &
DRAIN PAN
COMPARTMENT

CostGard™
CONDENSATE DRAIN SEAL
MODEL C40BV-15-88

FILTERS

HUMIDIFIER
COMPARTMENT

CostGard™
CONDENSATE DRAIN SEAL
MODEL C40BV-15-88

OVERVIEW
(SEE DRAWING #547 FOR
INSTRUCTION DETAILS)

CAUTION SUGGESTED HOLE SAW CONFIGURATION FOR DOUBLE WALL CONSTRUCTION

TO PREVENT POSSIBLE DAMAGE TO INTERNAL COMPONENTS:
(1) INSERT BLOCK BEHIND INSIDE PANEL; (2) BIT DEPTH LESS THAN 1/4".

NOTES:

1. INSTALL PIPE SUPPORTS AS NECESSARY TO ENSURE PIPING INTEGRITY.
2. ROUTE ALL PIPING TO AVOID ACCESS PANELS.
3. CONNECTION TO SUPPLY AIR COMPARTMENT MAY VARY.
4. DO NOT ALLOW PIPES TO PROTRUDE THROUGH GROMMETS MORE THAN 3/4".
5. ALLOW 1/8" / FT. SLOPE BETWEEN **CostGard™** AND FLOOR DRAIN.
6. ONCE THE COMPONENTS ARE ASSEMBLED, EACH CONNECTING JOINT MUST BE BONDED WITH PVC CEMENT.

WARNING LABEL

CostGard™
CONDENSATE DRAIN SEAL
MODEL B50-15-55

SUPPLY
DUCT

AIR ENTERPRISES

CONFIDENTIAL PROPERTY OF
TRENT TECHNOLOGIES, INC., 15939 FM 2493, TYLER, TEXAS 75703
NOT TO BE DISCLOSED TO OTHERS, COPIED, OR USED FOR ANY REASON
EXCEPT AS AUTHORIZED

TITLE
CostGard™ CONDENSATE DRAIN SEAL
POSSIBLE INSTALLATION ARRANGEMENT

SCALE NONE	DRAWING NO. 546	DATE: 10/9/18
---------------	---------------------------	------------------

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES	SHEET 1 OF 1
--	--------------